

Energy performance certificate (EPC)

55 Moneysharvan Road MAGHERA BT46 5PY	Energy rating F	Valid until: 10 November 2032 <hr/> Certificate number: 2151-1812-5123-1011-8581
---	---------------------------	---

Property type
 Detached bungalow

Total floor area
 94 square metres

Energy efficiency rating for this property

This property’s current energy rating is F. It has the potential to be D.

[See how to improve this property’s energy performance.](#)

Score	Energy rating	Current	Potential
92+	A		
81-91	B		
69-80	C		
55-68	D		57 D
39-54	E		
21-38	F	35 F	
1-20	G		

The graph shows this property’s current and potential energy efficiency.

Properties are given a rating from A (most efficient) to G (least efficient).

Properties are also given a score. The higher the number the lower your fuel bills are likely to be.

For properties in Northern Ireland:

- the average energy rating is D
- the average energy score is 60

Breakdown of property's energy performance

This section shows the energy performance for features of this property. The assessment does not consider the condition of a feature and how well it is working.

Each feature is assessed as one of the following:

- very good (most efficient)
- good
- average
- poor
- very poor (least efficient)

When the description says "assumed", it means that the feature could not be inspected and an assumption has been made based on the property's age and type.

Feature	Description	Rating
Wall	Cavity wall, filled cavity	Average
Roof	Pitched, 100 mm loft insulation	Average
Window	Fully double glazed	Average
Main heating	Boiler and radiators, oil	Poor
Main heating control	Programmer, no room thermostat	Very poor
Hot water	From main system, no cylinder thermostat	Very poor
Lighting	Low energy lighting in all fixed outlets	Very good
Floor	Solid, no insulation (assumed)	N/A
Secondary heating	Room heaters, coal	N/A

Primary energy use

The primary energy use for this property per year is 370 kilowatt hours per square metre (kWh/m²).

► [What is primary energy use?](#)

Environmental impact of this property

This property's current environmental impact rating is F. It has the potential to be E.

Properties are rated in a scale from A to G based on how much carbon dioxide (CO₂) they produce.

Properties with an A rating produce less CO₂ than G rated properties.

An average household produces

6 tonnes of CO2

This property produces

9.7 tonnes of CO2

This property's potential production

6.6 tonnes of CO2

By making the [recommended changes](#), you could reduce this property's CO2 emissions by 3.1 tonnes per year. This will help to protect the environment.

Environmental impact ratings are based on assumptions about average occupancy and energy use. They may not reflect how energy is consumed by the people living at the property.

Improve this property's energy performance

By following our step by step recommendations you could reduce this property's energy use and potentially save money.

Carrying out these changes in order will improve the property's energy rating and score from F (35) to D (57).

▶ [Do I need to follow these steps in order?](#)



Step 1: Hot water cylinder thermostat

Typical installation cost

£200 - £400

Typical yearly saving

£24

Potential rating after completing step 1

36 | F

Step 2: Heating controls (room thermostat and TRVs)

Typical installation cost

£350 - £450

Typical yearly saving

£212

Potential rating after completing steps 1 and 2

46 | E

Step 3: Replace boiler with new condensing boiler

Typical installation cost

£2,200 - £3,000

Typical yearly saving

£226

Potential rating after completing steps 1 to 3

57 | D

Step 4: Solar water heating

Typical installation cost

£4,000 - £6,000

Typical yearly saving

£42

Potential rating after completing steps 1 to 4

59 | D

Step 5: Solar photovoltaic panels, 2.5 kWp

Typical installation cost

£3,500 - £5,500

Typical yearly saving

£286

Potential rating after completing steps 1 to 5

69 | C

Step 6: Wind turbine

Typical installation cost

£15,000 - £25,000

Typical yearly saving

£628

Potential rating after completing steps 1 to 6

89 | B

Paying for energy improvements

You might be able to get a grant from the [Boiler Upgrade Scheme \(https://www.gov.uk/guidance/check-if-you-may-be-eligible-for-the-boiler-upgrade-scheme-from-april-2022\)](https://www.gov.uk/guidance/check-if-you-may-be-eligible-for-the-boiler-upgrade-scheme-from-april-2022). This will help you buy a more efficient, low carbon heating system for this property.

[Find energy grants and ways to save energy in your home \(https://www.gov.uk/improve-energy-efficiency\)](https://www.gov.uk/improve-energy-efficiency).

Estimated energy use and potential savings

Estimated yearly energy cost for this property

£1417

Potential saving

£462

The estimated cost shows how much the average household would spend in this property for heating, lighting and hot water. It is not based on how energy is used by the people living at the property.

The potential saving shows how much money you could save if you [complete each recommended step in order](#).

Heating use in this property

Heating a property usually makes up the majority of energy costs.

Potential energy savings by installing insulation

The assessor did not find any opportunities to save energy by installing insulation in this property.

Contacting the assessor and accreditation scheme

This EPC was created by a qualified energy assessor.

If you are unhappy about your property's energy assessment or certificate, you can complain to the assessor directly.

If you are still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation schemes are appointed by the government to ensure that assessors are qualified to carry out EPC assessments.

Assessor contact details

Assessor's name

Declan Diamond

Telephone

07921002828

Email

declandiamond@hotmail.com

Accreditation scheme contact details

Accreditation scheme

ECMK

Assessor ID

ECMK300674

Telephone

0333 123 1418

Email

info@ecmk.co.uk

Assessment details

Assessor's declaration

No related party

Date of assessment

11 November 2022

Date of certificate

11 November 2022

Type of assessment

▶ [RdSAP](#)

Other certificates for this property

If you are aware of previous certificates for this property and they are not listed here, please contact us at dluhc.digital-services@levellingup.gov.uk or call our helpdesk on 020 3829 0748 (Monday to Friday, 9am to 5pm).

There are no related certificates for this property.