

Energy performance certificate (EPC)

26 Willowholme Drive BELFAST BT6 8PA	Energy rating E	Valid until: 27 February 2035
		Certificate number: 8820-2524-0084-3103-0563

Property type	End-terrace house
Total floor area	60 square metres

Energy rating and score

This property's energy rating is E. It has the potential to be E.

[See how to improve this property's energy efficiency.](#)

Score	Energy rating	Current	Potential
92+	A		
81-91	B		
69-80	C		
55-68	D		
39-54	E	39 E	52 E
21-38	F		
1-20	G		

The graph shows this property's current and potential energy rating.

Properties get a rating from **A (best)** to **G (worst)** and a **score**. The better the rating and score, the lower your energy bills are likely to be.

For properties in Northern Ireland:

- the average energy rating is D
- the average energy score is 60

Breakdown of property's energy performance

Features in this property

Features get a rating from very good to very poor, based on how energy efficient they are. Ratings are not based on how well features work or their condition.

Assumed ratings are based on the property's age and type. They are used for features the assessor could not inspect.

Feature	Description	Rating
Wall	Solid brick, as built, no insulation (assumed)	Very poor
Roof	Pitched, 100 mm loft insulation	Average
Window	Fully double glazed	Average
Main heating	Boiler and radiators, oil	Average
Main heating control	Room thermostat only	Poor
Hot water	From main system, no cylinder thermostat	Poor
Lighting	Low energy lighting in all fixed outlets	Very good
Floor	Suspended, no insulation (assumed)	N/A
Secondary heating	None	N/A

Primary energy use

The primary energy use for this property per year is 368 kilowatt hours per square metre (kWh/m2).

► [About primary energy use](#)

How this affects your energy bills

An average household would need to spend **£1,364 per year on heating, hot water and lighting** in this property. These costs usually make up the majority of your energy bills.

You could **save £314 per year** if you complete the suggested steps for improving this property's energy rating.

This is **based on average costs in 2025** when this EPC was created. People living at the property may use different amounts of energy for heating, hot water and lighting.

Impact on the environment

This property's environmental impact rating is F. It has the potential to be E.

Properties get a rating from A (best) to G (worst) on how much carbon dioxide (CO2) they produce each year.

Carbon emissions

An average household produces	6 tonnes of CO2
This property produces	5.8 tonnes of CO2
This property's potential production	4.4 tonnes of CO2

You could improve this property's CO2 emissions by making the suggested changes. This will help to protect the environment.

These ratings are based on assumptions about average occupancy and energy use. People living at the property may use different amounts of energy.

Steps you could take to save energy

► [Do I need to follow these steps in order?](#)

Step 1: Increase loft insulation to 270 mm

Typical installation cost £100 - £350

Typical yearly saving £25

Potential rating after completing step 1

40 E

Step 2: Hot water cylinder insulation

Increase hot water cylinder insulation

Typical installation cost £15 - £30

Typical yearly saving £50

Potential rating after completing steps 1 and 2

42 E

Step 3: Hot water cylinder thermostat

Typical installation cost £200 - £400

Typical yearly saving £108

Potential rating after completing steps 1 to 3

46 E

Step 4: Heating controls (programmer and TRVs)

Typical installation cost £350 - £450

Typical yearly saving £38

Potential rating after completing steps 1 to 4

48 E

Step 5: Floor insulation (suspended floor)

Typical installation cost £800 - £1,200

Typical yearly saving £66

Potential rating after completing steps 1 to 5

51 E

Step 6: Heat recovery system for mixer showers

Typical installation cost £585 - £725

Typical yearly saving

£27

Potential rating after completing steps 1 to 6**52 E****Step 7: Solar water heating****Typical installation cost**

£4,000 - £6,000

Typical yearly saving

£68

Potential rating after completing steps 1 to 7**56 D****Step 8: Internal or external wall insulation****Typical installation cost**

£4,000 - £14,000

Typical yearly saving

£341

Potential rating after completing steps 1 to 8**72 C****Step 9: Gas condensing boiler****Typical installation cost**

£3,000 - £7,000

Typical yearly saving

£26

Potential rating after completing steps 1 to 9**77 C****Step 10: Solar photovoltaic panels, 2.5 kWp****Typical installation cost**

£3,500 - £5,500

Typical yearly saving

£467

Potential rating after completing steps 1 to 10**89 B****Who to contact about this certificate****Contacting the assessor**

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name

Patricia Best

Telephone

07788 108883

Emailpatricia@bestpropertysurveys.com**Contacting the accreditation scheme**

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Quidos Limited
Assessor's ID	QUID211599
Telephone	01225 667 570
Email	info@quidos.co.uk

About this assessment

Assessor's declaration	No related party
Date of assessment	27 February 2025
Date of certificate	28 February 2025
Type of assessment	► RdSAP

Other certificates for this property

If you are aware of previous certificates for this property and they are not listed here, please contact us at mhclg.digital-services@communities.gov.uk or call our helpdesk on 020 3829 0748 (Monday to Friday, 9am to 5pm).

There are no related certificates for this property.

[Help \(/help\)](#) [Accessibility \(/accessibility-statement\)](#) [Cookies \(/cookies\)](#)

[Give feedback \(https://forms.office.com/e/KX25htGMX5\)](https://forms.office.com/e/KX25htGMX5) [Service performance \(/service-performance\)](#)

OGL

All content is available under the [Open Government Licence v3.0](#)

(<https://www.nationalarchives.gov.uk/doc/open-government-licence/version/3/>), except where otherwise stated



[ht \(https://www.nationalarchives.gov.uk/information-management/re-using-public-sector-information/uk-government-licensing-framework\)](https://www.nationalarchives.gov.uk/information-management/re-using-public-sector-information/uk-government-licensing-framework)