

[illegible]

CONSTRUCTION SHOWN IN BOLD LINES IS ACCEPTED AS PROVIDING A MINIMUM OF 1/2 HOUR FIRE RESISTANCE, UNLESS OTHERWISE INDICATED. DOORS SHOWN IN BOLD LINES ARE ACCEPTED AS PROVIDING A MINIMUM OF 1 HOUR FIRE RESISTANCE. THEY MUST BE EFFECTIVELY MAINTAINED AS SELF-CLOSING, OR AS IN THE CASE OF STORE DOORS, KEPT LOCKED SHUT WHEN NOT IN USE. THE APPROPRIATE NOTICE IS DISPLAYED ON ALL FIRE DOORS.

HEALTH AND SAFETY EXECUTIVE
FOR NORTHERN IRELAND
BELFAST B16 9PL
TELEPHONE (0121) 29 1533
MEANS OF ESCAPE IN CASE OF FIRE

NAME AND ADDRESS
WHITESTEP TOWERS
CARBONIX DOCK
BELFAST
FIRST FLOOR PLAIN

FL FIREWORKS MAGAZIN
CONTRACT REFERENCE CODE
OWNER AND MAKERS
0520401
2 of 9

THE FIRE SERVICES (NORTHERN IRELAND)
ORDER 1984 NO.1821

ISSUED BY
DATE
APRIL 2002
11-00
APPROVED OFFICER
R. MCKAY
THE PLAIN WORKS UNIT OF
FIRE CERTIFICATE NUMBER:
FC 001 02