



FIRE CERTIFICATE FC 003 0  
DRAWING No. 1 of 6  
AMENDED 12th MAY 2005

AMENDED 12th MAY 2005

AMENDED 12th MAY 2005

[illegible]

CONSTRUCTION SHOWN IN BOLD LINES IS ACCEPTED.  
PRODUCING A MINIMUM OF 1/2 HOUR FIRE RESISTANCE  
UNLESS OTHERWISE INDICATED. DOORS SHOWN IN BOLD  
LINES ARE ACCEPTED AS PROVIDING A MINIMUM OF 1  
HOUR FIRE RESISTANCE. THEY MUST BE EFFECTIVELY  
MAINTAINED AS SELF-CLOSING OR AS IN THE CASE  
STORE DOORS, KEPT LOCKED SHUT WHEN NOT IN USE.  
THE APPROPRIATE NOTICE IS DISPLAYED ON ALL FIRE  
DOORS.

HEALTH AND SAFETY EXECUTIVE  
FOR NORTHERN IRELAND  
BELFAST BT6 9YU  
TELEPHONE (01232) 261555

MEANS OF ESCAPE IN CASE OF FIRE

NAME AND ADDRESS  
WINTERSEY, TONDER  
CLARENDON DOCK  
BELFAST  
GROUND FLOOR PLAIN

FIRE RESISTANCE MATERIAL USED  
CONCRETE  
FLOORING  
SPRINKLER SYSTEM

THE FIRE SERVICES (NORTHERN IRELAND)  
ORDER 1984 NO.1821

ISSUED BY  
DATE  
SCALE

APPROVED DESIGN  
THE PLAIN FLOOR PANEL OF  
FIRE RESISTANCE MATERIAL

DATE  
APRIL, 2002  
1:100

R. MCKAY

IT 001 02