


1 Stair 2
2 Mrs approx 12m
3 Eldon

| | | | |
|---|---|---|---|
| WP | Weather protection | | Fire resisting construction 30 minutes minimum |
| | Fire resisting doors 30 minutes minimum | 60 | Fire resisting construction 60 minutes minimum |
| 60 | Fire resisting doors 60 minutes minimum | // | Internal Glazing |
| VL | Vertical ladder | HRL | Handrail |
| VP | Vision panel | GRL | Guardrail |
| PEL | Panic escape latches | PB | Push bar to open |
| EOD | Easy opening devices | OO | Outward opening |
| SC | Self closing devices | DS | Double swing |
| SC/A | Automatic releases | FRG | Fire resisting glazing |
| FFF | Free from footerings | FR | Fire resisting |
| | Fire extinguisher water type | | |
| | Fire extinguisher foam type | | |
| | Fire extinguisher dry powder type | | |
| | Fire extinguisher carbon dioxide type | | |
| | Fire extinguisher vapourising liquid type | | |
| | Fire extinguisher aqueous film forming foam type | | |
| | Fire blanket | | Sand bucket |
| | Hose reel | | Fire alarm call point |
| | Audible warning devices | | Visual warning devices |
| | Exchange telephone | | Manual fire alarm sounder |
| | Internal telephone alarm system | | |
| | Automatic smoke detector | | |
| | Automatic heat detector | | Door Release Break Glass |
| | Emergency lighting points | | |
| | Illuminated exit boxes | | |
| | Illuminated exit boxes with directional arrow | | |
| E | Fire exit sign | | |
| E | Fire exit sign with directional sign | | |
| | Automatic control panel threaded key (circle fire door) | | |
| I | Intumescent point (Hamren) | | |
| FA1 | Fire Action (General) | | Available From Construction Service Fire Section |
| FA2 | Fire Action (Telephone Operators) | | |
| FA3 | Fire Action (Gate Keepers,Door Keepers and Receptionists) | | |
| FA4 | Fire Action (Reprographic and Print Room) | | |
| FA5 | Fire Action (Guest Bedrooms) | | |
| M1 | "Slide to open" notice | | |
| M2 | "Fire escape-keep clear" notice | | |
| M3 | "Fire door-keep shut" notice | | |
| M4 | "Push bar to open" notice | | |
| M5 | Door secured in open position notice | | |
| M6 | "Fire door-keep locked shut" notice | | |
| | Indicator panel | | Key in glass box |
| H | Hydrant | DR | Dry riser |
| K | Key in glass fronted box | | Tannoy speaker |
| | Outside Light | | |

CONSTRUCTION SHOWN IN BOLD LINES IS ACCEPTED AS PROVIDING A MINIMUM OF 1/2 HOUR FIRE RESISTANCE, UNLESS OTHERWISE INDICATED. DOORS SHOWN IN BOLD LINES ARE ACCEPTED AS PROVIDING A MINIMUM OF 1/2 HOUR FIRE RESISTANCE. THEY MUST BE EFFECTIVELY MAINTAINED AS SELF-CLOSING, OR AS IN THE CASE OF STORE DOORS "KEPT LOCKED SHUT" WHEN NOT IN USE. THE APPROPRIATE NOTICE IS DISPLAYED ON ALL FIRE DOORS.

HEALTH AND SAFETY EXECUTIVE
FOR NORTHERN IRELAND
83 LADAS DRIVE
BELFAST BT6 9FJ
TELEPHONE (01232) 251333

MEANS OF ESCAPE IN CASE OF FIRE

NAME AND ADDRESS
WATERSIDE TOWER
CLARENDON DOCK
BELFAST

FIRST FLOOR PLAN

| | |
|---|---|
| FILE REFERENCE NUMBER | |
| COMPUTER REFERENCE CODE | 6092w101 |
| DRAWING SHEET NUMBER | 2 of 6 |

THE FIRE SERVICES (NORTHERN IRELAND) ORDER 1984 NO.1821

| | |
|---|---|
| PREPARED BY | DW |
| DATE | APRIL 2002 |
| SCALE | 1:100 |
| INSPECTING OFFICER | R McKAY |
| THIS PLAN FORMS PART OF FIRE CERTIFICATE NUMBER: | FC 003 02 |

FIRE CERTIFICATE FC 003 02
DRAWING No. 2 of 6
AMENDED 12th MAY 2005