



FIRE CERTIFICATE FC 003 0
DRAWING No. 1 of 6
AMENDED 12th MAY 2005

AMENDED 12th MAY 2005

AMENDED 12th MAY 2005

[illegible]

CONSTRUCTION SHOWN IN BOLD LINES IS ACCEPTED. PROVIDING A MINIMUM OF 1/2 HOUR FIRE RESISTANCE UNLESS OTHERWISE INDICATED. DOORS SHOWN IN BOLD LINES ARE ACCEPTED AS PROVIDING A MINIMUM OF 1 HOUR FIRE RESISTANCE. THEY MUST BE EFFECTIVELY MAINTAINED AS SELF-CLOSING, OR AS IN THE CASE STORE DOORS, NEET LOOKED SHUT WHEN NOT IN USE. THE APPROPRIATE NOTICE IS DISPLAYED ON ALL FIRE DOORS.

HEALTH AND SAFETY EXECUTIVE PO BOX 10000 DUBLIN 10 TELEPHONE (01) 232 2533 FAX (01) 232 2533	NAME AND ADDRESS MCCARTHY TOWERS CLARENCE DOCK DUBLIN 1 D02 YK11	DATE APRIL 2002 1100	THE MAY 2002
THE HEALTH AND SAFETY COMMISSION PO BOX 10000 DUBLIN 10	THE FIRE SERVICE (NORTHERN IRELAND) 199A PEARL NO.121	THE MAY 2002 1100	THE MAY 2002