



FIRE CERTIFICATE FC 003 02
DRAWING No. 4 of 6
AMENDED 12th MAY 2005

HEALTH AND SAFETY DECLARATION	
FOR NOTIFICATION PURPOSES	
TELEPHONE (0)202 703333	
BELOFT 001 001	
MEANS OF ESCAPE IN CASE OF FIRE	
NAME AND ADDRESS	
MATROUSE DOME	
CLEVERDON DOME	
FLIGHT	
THIRD FLOOR PLAN	
FILE REFERENCE NUMBER	6020403
FILE REFERENCE CODE	4 0 0 1
PRINTED FILE NUMBER	6020403
THE FIRE SERVICES (NOTIFICATION RELATION)	
ORDER 1984 MAY 1984	
NOTIFIED BY	MR
DATE	11-01-2000
NOTIFYING OFFICE	R MAYAT
THE SIGNATURE PART OF	
THE CERTIFICATE NUMBER	FC 002 02

CONSTRUCTION SHOWN IN BOLD LINES IS ACCEPTED AS PROVIDING A MINIMUM OF 1/2 HOUR FIRE RESISTANCE. UNLESS OTHERWISE INDICATED, DOORS SHOWN IN BOLD LINES ARE ACCEPTED AS PROVIDING A MINIMUM OF 1/2 HOUR FIRE RESISTANCE; THEY MUST BE EFFECTIVELY MAINTAINED AS SELF-CLOSING, OR AS IN THE CASE OF STORM DOORS KEPT LOCKED SHUT WHEN NOT IN USE. THE APPROPRIATE NOTICE IS DISPLAYED ON ALL FIRE DOORS.

[illegible][illegible]