



FIRE CERTIFICATE FC 003 0
DRAWING No. 1 of 6
AMENDED 12th MAY 2005

AMENDED 12th MAY 2005

AMENDED 12th MAY 2005

[illegible]

CONSTRUCTION SHOWN IN BOLD LINES IS ACCEPTED. PRODUCING A MINIMUM OF 1/2 HOUR FIRE RESISTANCE UNLESS OTHERWISE INDICATED. DOORS SHOWN IN BOLD LINES ARE ACCEPTED AS PROVIDING A MINIMUM OF 1 HOUR FIRE RESISTANCE. THEY MUST BE EFFECTIVELY MAINTAINED AS SELF-CLOSING OR AS IN THE CASE STORE DOORS, KEPT LOCKED SHUT WHEN NOT IN USE. THE APPROPRIATE NOTICE IS DISPLAYED ON ALL FIRE DOORS.

HEALTH AND SAFETY EXECUTIVE
FOR NORTHERN IRELAND
BELFAST BT6 9YU
TELEPHONE (01232) 351555

MEANS OF ESCAPE IN CASE OF FIRE

NAME AND ADDRESS
WINTERSEY TOWERS
CLARENDON DOCK
BELFAST
GROUND FLOOR PLAIN

FIRE RESISTANCE MATERIAL USED
CONCRETE
FLOORING
SPRINKLER SYSTEM

THE FIRE SERVICES (NORTHERN IRELAND)
ORDER 1984 NO.1821

ISSUED BY
DATE
SCALE

APPROVED DESIGN
THE PLAIN FLOOR PART OF
FIRE CERTIFICATE NUMBER

DATE
APRIL, 2002
1:100

R. MCKAY

IT 001 02