

Energy Performance Certificate

Non-Domestic Building

Northern Ireland

18-20, The Diamond
NEWTOWNABBEY
BT37 9BJ

Certificate Reference Number:
0690-9005-4930-2890-4503

This certificate shows the energy rating of this building. It indicates the energy efficiency of the building fabric and the heating, ventilation, cooling and lighting systems. The rating is compared to two benchmarks for this type of building: one appropriate for new buildings and one appropriate for existing buildings. There is more advice on how to interpret this information on the Department's website www.epb.dfpni.gov.uk.

Energy Performance Asset Rating

More energy efficient

A+

..... Net zero CO₂ emissions

A 0-25

B 26-50

C 51-75

D 76-100

◀ 98

This is how energy efficient
the building is.

E 101-125

F 126-150

G Over 150

Less energy efficient

Technical Information

Main heating fuel:	Grid Supplied Electricity
Building environment:	Heating and Natural Ventilation
Total useful floor area (m ²):	211
Building complexity (NOS level):	3
Building emission rate (kgCO ₂ /m ²):	63.58

Benchmarks

Buildings similar to this one
could have rating as follows:

26

If newly built

70

If typical of the
existing stock

Administrative Information

This is an Energy Performance Certificate as defined in SR 2008 as amended.

Assessment Software: iSBEM v4.1.e using calculation engine SBEM v4.1.e.5

Property Reference: 404860950000

Assessor Name: Barry McCaffrey - FMC Services Ltd

Assessor Number: STRO000276

Accreditation Scheme: Stroma Accreditation

Employer/Trading Name: FMC Services Ltd

Employer/Trading Address: 6 Moylagh Meadows, Beragh, Co.Tyrone, BT79 0UG

Issue Date: 23 Oct 2015

Valid Until: 22 Oct 2025 (unless superseded by a later certificate)

Related Party Disclosure: Not related to the owner.

Recommendations for improving the property are contained in Report Reference Number: 9900-4986-0445-5290-0004

If you have a complaint or wish to confirm that the certificate is genuine

Details of the assessor and the relevant accreditation scheme are on the certificate. You can get contact details of the accreditation scheme from the Department's website at www.epb.dfpni.gov.uk, together with details of the procedures for confirming authenticity of a certificate and for making a complaint.



For advice on how to take action and to find out about technical and financial assistance schemes to help make buildings more energy efficient visit www.carbontrust.co.uk or call us on **0800 085 2005**.