

# Energy performance certificate (EPC)

4 Saul Road  
DOWNPATRICK  
BT30 6NN

Energy rating

**F**

Valid until:

**14 August 2034**

Certificate number:

**1000-6954-0922-7490-3843**

Property type

Detached house

Total floor area

99 square metres

## Energy rating and score

This property's energy rating is F. It has the potential to be D.


[See how to improve this property's energy efficiency.](#)

The graph shows this property's current and potential energy rating.

**Properties get a rating from A (best) to G (worst) and a score.** The better the rating and score, the lower your energy bills are likely to be.

For properties in Northern Ireland:

the average energy rating is D  
the average energy score is 60



## Breakdown of property's energy performance

### Features in this property

Features get a rating from very good to very poor, based on how energy efficient they are. Ratings are not based on how well features work or their condition.

Assumed ratings are based on the property's age and type. They are used for features the assessor could not inspect.

Feature	Description	Rating
Wall	Cavity wall, as built, no insulation (assumed)	Poor
Roof	Pitched, insulated at rafters	Average
Roof	Roof room(s), insulated	Very poor
Window	Fully double glazed	Average
Main heating	Boiler and radiators, oil	Average
Main heating control	Programmer, TRVs and bypass	Average
Hot water	From main system, no cylinder thermostat	Poor
Lighting	Low energy lighting in 90% of fixed outlets	Very good
Floor	Suspended, no insulation (assumed)	N/A
Secondary heating	Room heaters, coal	N/A

### Primary energy use

The primary energy use for this property per year is 317 kilowatt hours per square metre (kWh/m<sup>2</sup>).

### Additional information

Additional information about this property:

- Cavity fill is recommended

---

## How this affects your energy bills

An average household would need to spend **£2,127 per year on heating, hot water and lighting** in this property. These costs usually make up the majority of your energy bills.

You could **save £794 per year** if you complete the suggested steps for improving this property's energy rating.

This is **based on average costs in 2024** when this EPC was created. People living at the property may use different amounts of energy for heating, hot water and lighting.

---

## Impact on the environment

This property's environmental impact rating is F. It has the potential to be E.

Properties get a rating from A (best) to G (worst) on how much carbon dioxide (CO2) they produce each year.

## Carbon emissions

An average household produces 6 tonnes of CO2

This property produces 8.7 tonnes of CO2

This property's potential production 5.3 tonnes of CO2

You could improve this property's CO2 emissions by making the suggested changes. This will help to protect the environment.

These ratings are based on assumptions about average occupancy and energy use. People living at the property may use different amounts of energy.

## Steps you could take to save energy

Step	Typical installation cost	Typical yearly saving
1. Cavity wall insulation	£500 - £1,500	£180
2. Hot water cylinder thermostat	£200 - £400	£35
3. Heating controls (room thermostat)	£350 - £450	£100
4. Room-in-roof insulation	£1,500 - £2,700	£330
5. Floor insulation (suspended floor)	£800 - £1,200	£150
6. Solar water heating	£4,000 - £6,000	£93
7. Solar photovoltaic panels	£3,500 - £5,500	£521

## Help paying for energy improvements

You might be able to get a grant from the [Boiler Upgrade Scheme \(https://www.gov.uk/apply-boiler-upgrade-scheme\)](https://www.gov.uk/apply-boiler-upgrade-scheme). This will help you buy a more efficient, low carbon heating system for this property.



## Who to contact about this certificate

### Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Matthew Jackson
Telephone	07422696930
Email	<a href="mailto:mjackson@eppbelfast.com">mjackson@eppbelfast.com</a>

### Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Elmhurst Energy Systems Ltd
Assessor's ID	EES/024461
Telephone	01455 883 250
Email	<a href="mailto:enquiries@elmhurstenergy.co.uk">enquiries@elmhurstenergy.co.uk</a>

### About this assessment

Assessor's declaration	No related party
Date of assessment	15 August 2024
Date of certificate	15 August 2024
Type of assessment	<a href="#">RdSAP</a>