

# Energy Performance Certificate

Non-Domestic Building

Northern Ireland

COMMERCIAL UNIT 2  
8 Causeway Street  
PORTRUSH  
BT56 8AB

Certificate Reference Number:  
0251-0231-9209-5904-3006

This certificate shows the energy rating of this building. It indicates the energy efficiency of the building fabric and the heating, ventilation, cooling and lighting systems. The rating is compared to two benchmarks for this type of building: one appropriate for new buildings and one appropriate for existing buildings. There is more advice on how to interpret this information on the website for the Department of Finance at [www.finance-ni.gov.uk](http://www.finance-ni.gov.uk).

## Energy Performance Asset Rating

More energy efficient

A+

..... Net zero CO<sub>2</sub> emissions

A 0-25

B 26-50

C 51-75

D 76-100

E 101-125

F 126-150

G Over 150

Less energy efficient

◀ 102

This is how energy efficient  
the building is.

## Technical Information

|  |                                 |
|--|---------------------------------|
| Main heating fuel:   | Grid Supplied Electricity       |
| Building environment:  | Heating and Natural Ventilation |
| Total useful floor area (m <sup>2</sup> ):                           | 244                             |
| Building complexity (NOS level):                                     | 3                               |
| Building emission rate (kgCO <sub>2</sub> /m <sup>2</sup> per year): | 73.84                           |
| Primary energy use (kWh/m <sup>2</sup> per year):                    | 417.06                          |

## Benchmarks

Buildings similar to this one  
could have rating as follows:

55

If newly built

147

If typical of the  
existing stock

## Administrative Information

This is an Energy Performance Certificate as defined in the Energy Performance of Buildings (Certificates and Inspections) Regulations (Northern Ireland) 2008 (as amended).

|                                  |   |
|----------------------------------|---|
| <b>Assessment Software:</b>      | iSBEM v4.1.g using calculation engine SBEM v4.1.g.0     |
| <b>Property Reference:</b>       | 550232990001  |
| <b>Assessor Name:</b>            | Philip Hobson   |
| <b>Assessor Number:</b>          | EES/015699  |
| <b>Accreditation Scheme:</b>     | Elmhurst Energy Systems                                 |
| <b>Employer/Trading Name:</b>    | Elmhurst Energy Systems Ltd                             |
| <b>Employer/Trading Address:</b> | 16 St Johns Business Park, Lutterworth, Leics, LE17 4HB |
| <b>Issue Date:</b>               | 09 Apr 2019   |
| <b>Valid Until:</b>              | 08 Apr 2029 (unless superseded by a later certificate)  |
| <b>Related Party Disclosure:</b> | Not related to the owner.                               |

**Recommendations for improving the property are contained in Report Reference Number: 0040-5923-0401-9291-2050**

## If you have a complaint or wish to confirm that the certificate is genuine

Details of the assessor and the relevant accreditation scheme are on the certificate. You can get the contact details of the accreditation scheme from the website for the Department of Finance at [www.finance-ni.gov.uk](http://www.finance-ni.gov.uk), together with details of the procedures for confirming authenticity of a certificate and for making a complaint.