

Where chimney passes through roof covering provide code 4 tray to be fitted through entire chimney. Tray to step up at back and sides of stack and at junction with flue liners.

Black Truton Slates On
40 X 20 Battens On Builders
Felt To B.S.747.



T ELEVATION

The threshold at the Principle Entrance shall not exceed 15mm and to have a clear opening not less than 775mm wide. Disabled access can be provided to the rear in this rural setting where it is traditional to visit the dwelling via the rear door-a motor car can be driven to the rear door with ease.

Provide level access to principal entrance. Sloped surface to entrance to be firm & even & with no obstruction width not less than 900mm. landing area to be 1200mm. Gradient not more than 1 in 12.5.

